

**SITE INVESTIGATION  
DYNAMIC CONE PENETROMETER RESULTS**

<b>Site:</b>	DIMBOOLA RECREATION RESERVE
	NETBALL CHANGEROOMS
	DIMBOOLA.

Job No.	6061SI
Technician	D.N.
Date:	4.6.17

DC1					
No. of Blows	Reading	mm/blow	Avg Pen (mm)	Degree of Density	Depth (mm)
	0				
5	140	28	20-42	med dense	<b>140</b>
10	290	15	10-20	dense	<b>500</b>
10	500	21			
10	960	46	43-70	loose	<b>960</b>
10	1180	22	20-42	med dense	<b>1180</b>
10	1270	9	10-20	dense	<b>2000</b>
10	1370	10			
10	1470	10			
10	1560	9			
10	1670	11			
10	1760	9			
10	1880	12			
10	2000	12			

DC2					
No. of Blows	Reading	mm/blow	Avg Pen (mm)	Degree of Density	Depth (mm)
	0				
5	140	28	20-42	med. dense	<b>140</b>
10	300	16	10-20	dense	<b>300</b>
10	700	40	20-42	medium dense	<b>1200</b>
10	1010	31			
10	1200	19	10-20	dense	<b>2590</b>
10	1310	11			
10	1400	9			
10	1480	8			
10	1590	11			
10	1690	10			
10	1780	9			
10	1880	10			
10	1990	11			
10	2090	10			
10	2190	10			
10	2290	10			
10	2390	10			
10	2480	9			
10	2590	11			
10	2680	9	<10	very dense	<b>3000</b>
10	2750	7			
10	2800	5			
10	2880	8			
10	2950	7			
10	3000	5			